#### § 63.422

potential to emit as defined in §63.2 of subpart A of this part.

Operating parameter value means a value for an operating or emission parameter of the vapor processing system (e.g., temperature) which, if maintained continuously by itself or in combination with one or more other operating parameter values, determines that an owner or operator has complied with the applicable emission standard. The operating parameter value is determined using the procedures outlined in §63.425(b).

Oxygenated gasoline means the same as defined in 40 CFR 80.2(rr).

Pipeline breakout station means a facility along a pipeline containing storage vessels used to relieve surges or receive and store gasoline from the pipeline for reinjection and continued transportation by pipeline or to other facilities.

Reformulated gasoline means the same as defined in 40 CFR 80.2(ee).

Uncontrolled loading rack means a loading rack used to load gasoline cargo tanks that is not a controlled loading rack.

Vapor-tight gasoline cargo tank means a gasoline cargo tank which has demonstrated within the 12 preceding months that it meets the annual certification test requirements in \$63.425(e), and which is subject at all times to the test requirements in \$63.425(f), (g), and (h).

Volatile organic liquid (VOL) means, for the purposes of this subpart, gasoline.

 $[59\ FR\ 64318,\ Dec.\ 14,\ 1994,\ as\ amended\ at\ 62\ FR\ 9093,\ Feb.\ 28,\ 1997]$ 

# §63.422 Standards: Loading racks.

(a) Each owner or operator of loading racks at a bulk gasoline terminal subject to the provisions of this subpart shall comply with the requirements in §60.502 of this chapter except for paragraphs (b), (c), and (j) of that section. For purposes of this section, the term "affected facility" used in §60.502 of this chapter means the loading racks that load gasoline cargo tanks at the bulk gasoline terminals subject to the provisions of this subpart.

(b) Emissions to the atmosphere from the vapor collection and processing systems due to the loading of gasoline cargo tanks shall not exceed 10 milligrams of total organic compounds per liter of gasoline loaded.

(c) Each owner or operator of a bulk gasoline terminal subject to the provisions of this subpart shall comply with §60.502(e) of this chapter as follows:

(1) For the purposes of this section, the term "tank truck" as used in §60.502(e) of this chapter means "cargo tank."

(2) Section 60.502(e)(5) of this chapter is changed to read: The terminal owner or operator shall take steps assuring that the nonvapor-tight gasoline cargo tank will not be reloaded at the facility until vapor tightness documentation for that gasoline cargo tank is obtained which documents that:

(i) The gasoline cargo tank meets the applicable test requirements in §63.425(e);

(ii) For each gasoline cargo tank failing the test in §63.425 (f) or (g) at the facility, the cargo tank either:

(A) Before repair work is performed on the cargo tank, meets the test requirements in §63.425 (g) or (h), or

(B) After repair work is performed on the cargo tank before or during the tests in §63.425 (g) or (h), subsequently passes the annual certification test described in §63.425(e).

(d) Each owner or operator shall meet the requirements in all paragraphs of this section as expeditiously as practicable, but no later than December 15, 1997, at existing facilities and upon startup for new facilities.

[59 FR 64318, Dec. 14, 1994; 60 FR 32913, June 26, 1995]

## §63.423 Standards: Storage vessels.

(a) Each owner or operator of a bulk gasoline terminal or pipeline breakout station subject to the provisions of this subpart shall equip each gasoline storage vessel with a design capacity greater than or equal to 75 m³ according to the requirements in §60.112b(a) (1) through (4) of this chapter, except for the requirements in §§60.112b(a)(1) (iv) through (ix) and 60.112b(a)(2)(ii) of this chapter.

(b) Each owner or operator shall equip each gasoline external floating roof storage vessel with a design capacity greater than or equal to 75 m³ according to the requirements in

§60.112b(a)(2)(ii) of this chapter if such storage vessel does not currently meet the requirements in paragraph (a) of this section.

(c) Each gasoline storage vessel at existing bulk gasoline terminals and pipeline breakout stations shall be in compliance with the requirements in paragraphs (a) and (b) of this section as expeditiously as practicable, but no later than December 15, 1997. At new bulk gasoline terminals and pipeline breakout stations, compliance shall be achieved upon startup.

#### §63.424 Standards: Equipment leaks.

- (a) Each owner or operator of a bulk gasoline terminal or pipeline breakout station subject to the provisions of this subpart shall perform a monthly leak inspection of all equipment in gasoline service. For this inspection, detection methods incorporating sight, sound, and smell are acceptable. Each piece of equipment shall be inspected during the loading of a gasoline cargo tank.
- (b) A log book shall be used and shall be signed by the owner or operator at the completion of each inspection. A section of the log shall contain a list, summary description, or diagram(s) showing the location of all equipment in gasoline service at the facility.
- (c) Each detection of a liquid or vapor leak shall be recorded in the log book. When a leak is detected, an initial attempt at repair shall be made as soon as practicable, but no later than 5 calendar days after the leak is detected. Repair or replacement of leaking equipment shall be completed within 15 calendar days after detection of each leak, except as provided in paragraph (d) of this section.
- (d) Delay of repair of leaking equipment will be allowed upon a demonstration to the Administrator that repair within 15 days is not feasible. The owner or operator shall provide the reason(s) a delay is needed and the date by which each repair is expected to be completed.
- (e) Initial compliance with the requirements in paragraphs (a) through (d) of this section shall be achieved by existing sources as expeditiously as practicable, but no later than December 15, 1997. For new sources, initial

compliance shall be achieved upon startup.

- (f) As an alternative to compliance with the provisions in paragraphs (a) through (d) of this section, owners or operators may implement an instrument leak monitoring program that has been demonstrated to the Administrator as at least equivalent.
- (g) Owners and operators shall not allow gasoline to be handled in a manner that would result in vapor releases to the atmosphere for extended periods of time. Measures to be taken include, but are not limited to, the following:
  - (1) Minimize gasoline spills;
- (2) Clean up spills as expeditiously as practicable;
- (3) Cover all open gasoline containers with a gasketed seal when not in use;
- (4) Minimize gasoline sent to open waste collection systems that collect and transport gasoline to reclamation and recycling devices, such as oil/water separators.

[59 FR 64318, Dec. 14, 1994, as amended at 61 FR 7723, Feb. 29, 1996]

### §63.425 Test methods and procedures.

- (a) Each owner or operator subject to the emission standard in §63.422(b) or §60.112b(a)(3)(ii) of this chapter shall conduct a performance test on the vapor processing system according to the test methods and procedures in §60.503, except a reading of 500 ppm shall be used to determine the level of leaks to be repaired under §60.503(b). If a flare is used to control emissions, and emissions from this device cannot be measured using these methods and procedures, the provisions of §63.11(b) shall apply.
- (b) For each performance test conducted under paragraph (a) of this section, the owner or operator shall determine a monitored operating parameter value for the vapor processing system using the following procedure:
- (1) During the performance test, continuously record the operating parameter under §63.427(a);
- (2) Determine an operating parameter value based on the parameter data monitored during the performance test, supplemented by engineering assessments and the manufacturer's recommendations; and